

**Periodical Testing and checking of Meters under
SMP No- 34-07 - Progress for the Qtr ending Sept.'15**

Report on periodical testing of meters

Annexure 1

NAME OF DISCOM-M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal

Quarter ending - June'08

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION			Quarterly (June'15 ending) proposed Target	Quarterly achieved progress for each quarter of the year 15-16			percentage testing/certification during reporting year 15-16	
		Total no. of meters installed as on 01.04.15	No of meters due for testing Apr.'15 to Mar'16 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 15-16		Qtr ending June'15	Qtr ending Sept.'15	Total (Apr'15 to Mar'16)	Against the quarterly target	Against the total no of meters to be tested during the year 15-16
1	2	3	4	5	6	7	8	10	11	12
A	<u>HT</u>									
1	Bhopal	1266	1266	1266	317	335	327	662	103%	52%
2	Gwalior	616	616	616	154	157	178	335	116%	54%
	Central Discom	1882	1882	1882	471	492	505	997	107%	53%
B	<u>LT</u>									
	<i>1.Single Phase</i>									
1	Bhopal	1356957	271391	271391	67848	35302	30476	65778	45%	24%
2	Gwalior	929736	185947	185947	46487	30682	26805	57487	58%	31%
	Central Discom	2286693	457339	457339	114335	65984	57281	123265	50%	27%
	<i>2.Three Phase</i>									
1	Bhopal	140077	28015	28015	7004	9122	7683	16805	110%	60%
2	Gwalior	59382	11876	11876	2969	2472	2295	4767	77%	40%
	Central Discom	199459	39892	39892	9973	11594	9978	21572	100%	54%
	DISCOM (H.T.+ L.T.)	2488034	499112	499112	124778	78070	67764	145834	54%	29%

As per MPERC order 2013

LT single phase meter = once in every 5 years

LT three phase meter = once in every 5 years (As per supply code 2013)

HT meter = once a year

DY. GENERAL MANAGER (COM.II)
O/O MD (CZ), MPMKVCL, BHOPAL