

**Periodical Testing and checking of Meters under SMP No- 34-07 - Progress for the Qtr ending March'14**

**NAME OF DISCOM- M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal**

**Annexure 1**

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION				Quarterly achieved progress for each quarter of the year 13-14					percentage testing/certification during reporting year 13-14	
		Total no. of meters installed as on 01.04.13	No of meters due for testing Apr.'13 to Mar'14 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 13-14	Quarterly (Mar.'14 ending) proposed Target	Qtr ending June'13	Qtr ending Sept.'13	Qtr ending Dec.'13	Qtr. ending Mar'14	Total (Apr'13 to Mar'14)	Against the quarterly target	Against the total no of meters to be tested during the year 13-14
1	2	3	4	5	6	7	8	9	13	10	11	12
A	<u>HT</u>											
1	Bhopal	1118	1118	1118	280	274	228	361	255	1118	91%	100%
2	Gwalior	503	503	503	126	142	130	122	102	496	81%	99%
	<b>Central Discom</b>	<b>1621</b>	<b>1621</b>	<b>1621</b>	<b>405</b>	<b>416</b>	<b>358</b>	<b>483</b>	<b>357</b>	<b>1614</b>	<b>88%</b>	<b>100%</b>
B	<u>LT</u>											
	<i>1.Single Phase</i>											
1	Bhopal	1127796	225559	225559	56390	43984	25804	56070	43489	169347	77%	75%
2	Gwalior	785567	157113	157113	39278	19811	34420	31256	37233	122720	95%	78%
	<b>Central Discom</b>	<b>1913363</b>	<b>382673</b>	<b>382673</b>	<b>95668</b>	<b>63795</b>	<b>60224</b>	<b>87326</b>	<b>80722</b>	<b>292067</b>	<b>84%</b>	<b>76%</b>
	<i>2.Three Phase</i>											
1	Bhopal	194150	38830	38830	9708	13104	2867	11214	12046	39231	124%	101%
2	Gwalior	65124	13025	13025	3256	3925	3710	3161	3805	14601	117%	112%
	<b>Central Discom</b>	<b>259274</b>	<b>51855</b>	<b>51855</b>	<b>12964</b>	<b>17029</b>	<b>6577</b>	<b>14375</b>	<b>15851</b>	<b>53832</b>	<b>122%</b>	<b>104%</b>
	<b>DISCOM (H.T.+ L.T.)</b>	<b>2174258</b>	<b>436148</b>	<b>436148</b>	<b>109037</b>	<b>81240</b>	<b>67159</b>	<b>102184</b>	<b>96930</b>	<b>347513</b>	<b>89%</b>	<b>80%</b>

As per MPERC order dated 05-09-2008

LT single phase meter = once in every 5 years

LT three phase meter = once in every 5 years (As per supply code 2013)

HT meter = once a year

**GENERAL MANAGER (COM.II)**  
O/O MD (CZ), MPMKVCL, BHOPAL