

Periodical Testing and checking of Meters under SMP No- 34-07 - Progress for the Qtr ending Sept.'13

NAME OF DISCOM- M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal

Annexure 1

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION			Quarterly achieved progress for each quarter of the year 13-14			percentage testing/certification during reporting year 13-14		
		Total no. of meters installed as on 01.04.13	No of meters due for testing Apr.'13 to Mar'14 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 13-14	Quarterly (Sept'13 ending) proposed Target	Qtr ending June'13	Qtr ending Sept.'13	Total (Apr'13 to Mar'14)	Against the quarterly target	Against the total no of meters to be tested during the year 13-14
1	2	3	4	5	6	7	8	10	11	12
A	<u>HT</u>									
1	Bhopal	1118	1118	1118	280	274	228	502	82%	45%
2	Gwalior	503	503	503	126	142	130	272	103%	54%
	Central Discom	1621	1621	1621	405	416	358	774	88%	48%
B	<u>LT</u>									
	<i>1.Single Phase</i>									
1	Bhopal	1127796	225559	225559	56390	43984	25804	69788	46%	31%
2	Gwalior	785567	157113	157113	39278	19811	34420	54231	88%	35%
	Central Discom	1913363	382673	382673	95668	63795	60224	124019	63%	32%
	<i>2.Three Phase</i>									
1	Bhopal	194150	38830	38830	9708	13104	2867	15971	30%	41%
2	Gwalior	65124	13025	13025	3256	3925	3710	7635	114%	59%
	Central Discom	259274	51855	51855	12964	17029	6577	23606	51%	46%
	DISCOM (H.T.+ L.T.)	2174258	436148	436148	109037	81240	67159	148399	62%	34%

As per MPERC order dated 05-09-2008

LT single phase meter = once in every 5 years

LT three phase meter = once in every 5 years (As per supply code 2013)

HT meter = once a year

GENERAL MANAGER (COM.II)
O/O MD (CZ), MPMKVCL, BHOPAL