

S. No.	Region	Circle	December,2018 (No. of Feeders Having More Than 5 Tripping)
1	Bhopal	Betul	4
2		Bhopal (City)	7
3		Hoshangabad	26
4		Bhopal (O&M)	15
5		Raisen	15
6		Rajgarh	18
7		Sehore	5
8		Vidisha	15
TOTAL(BR)			105
9	Gwalior	Bhind	24
10		Guna	42
11		Gwalior (City)	2
12		Gwalior (O&M)	26
13		Morena	25
14		Sheopur	17
15		Shivpuri	18
TOTAL(GR)			154
GRAND TOTAL			259

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Betul Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performnce in % (Availability of feeder)
1	BETUL	132KV AMLA	33KV JAMBADA	5	03:11:00	99.57%
2	BETUL	132KV MULTAI	33KV INDUSTRIAL	7	01:46:00	99.76%
3	BETUL	220KV SARNI	33KV GHODADONGRI	11	07:35:00	98.98%
4	BETUL	220KV SARNI	33KV POWER HOUSE	8	15:16:00	97.95%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Bhind Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Availability of feeder)
1	BHIND	132KV BHIND	33KV AKODA	82	34:08:00	95.41%
2	BHIND	132KV BHIND	33KV BHAROLI	12	04:58:00	99.33%
3	BHIND	132KV BHIND	33KV INDUSTRIAL	28	38:06:00	94.88%
4	BHIND	132KV BHIND	33KV ITI RURAL	23	08:41:00	98.83%
5	BHIND	132KV BHIND	33KV PHOOP	47	16:26:00	97.79%
6	BHIND	132KV BHIND	33KV PRATAPPURA	20	12:28:00	98.32%
7	BHIND	132KV BHIND	33KV UMARI	6	09:59:00	98.66%
8	BHIND	132KV GOHAD	33KV FEEDER -V (CHITORA)	5	04:26:00	99.40%
9	BHIND	132KV GOHAD	33KV FEEDER-II (ENDORI)	9	19:58:00	97.32%
10	BHIND	132KV LAHAR	33KV LAHAR	7	05:09:00	99.31%
11	BHIND	132KV LAHAR	33KV MADORI	21	14:15:00	98.08%
12	BHIND	132KV LAHAR	33KV SHYAMPURA	33	14:45:00	98.02%
13	BHIND	132KV PRATAPPURA	33KV PRATAPPURA	24	13:02:00	98.25%
14	BHIND	132KV PRATAPPURA	33KV SURPURA	14	14:53:00	98.00%
15	BHIND	132KV ROUN	33KV MACHHAND	5	01:43:00	99.77%
16	BHIND	132KV ROUN	33KV MEHONA	11	09:53:00	98.67%
17	BHIND	132KV ROUN	33KV ROUN	9	07:54:00	98.94%
18	BHIND	220KV MEHGAON	33KV BHIND	14	11:40:00	98.43%
19	BHIND	220KV MEHGAON	33KV GATA	12	19:49:00	97.34%
20	BHIND	220KV MEHGAON	33KV GINGARKHI	19	21:54:00	97.06%
21	BHIND	220KV MEHGAON	33KV GOHAD	28	32:40:00	95.61%
22	BHIND	220KV MEHGAON	33KV GORMI	25	23:14:00	96.88%
23	BHIND	220KV MEHGAON	33KV MAU	11	12:39:00	98.30%
24	BHIND	220KV MEHGAON	33KV PIDORA	7	14:36:00	98.04%

EHV 5/s wise No. of 33kV feeders Interruption/Breakdown report of Bhopal City Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Avalability of feeder)
1	BHOPAL CITY	132KV AMRAWATKHURD	33KV KATARA-II	7	04:26:00	99.40%
2	BHOPAL CITY	132KV AYODHYA NGR	33KV ISRO	10	53:09:00	92.86%
3	BHOPAL CITY	132KV CHAMBAL	33KV A.I.R.	5	02:33:00	99.66%
4	BHOPAL CITY	132KV CHAMBAL	33KV BHEL	22	38:07:00	94.88%
5	BHOPAL CITY	132KV Lalghati	33KV LALGHATI-II	5	01:22:00	99.82%
6	BHOPAL CITY	132KV MACT	33KV BAIRAGARH CHICHLI-II	6	02:37:00	99.65%
7	BHOPAL CITY	220KV BHOPAL	33KV BERASIA	6	13:57:00	98.13%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Guna Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Availability of feeder)
1	GUNA	132KV Aron	33kv ARON	6	08:59:00	98.79%
2	GUNA	132KV Aron	33KV PANWARI	11	20:05:00	97.30%
3	GUNA	132KV Aron	33KV RAMPUR	10	03:56:00	99.47%
4	GUNA	132KV BHONRA	33KV BHONRA	7	03:00:00	99.60%
5	GUNA	132KV BHONRA	33KV COLONY	19	20:13:00	97.28%
6	GUNA	132KV BHONRA	33KV FATEHGARH	15	03:42:00	99.50%
7	GUNA	132KV BHONRA	33KV GADLA	7	02:46:00	99.63%
8	GUNA	132KV BHONRA	33KV KALORA	9	04:23:00	99.41%
9	GUNA	132KV BHONRA	33KV KAPASI	12	02:56:00	99.61%
10	GUNA	132KV BHONRA	33KV PARANTH	11	20:51:00	97.20%
11	GUNA	132KV BHONRA	33KV SAIN BOARD	8	02:18:00	99.69%
12	GUNA	132KV BIAORA	33KV KACHARI	9	8:34:00	98.85%
13	GUNA	132KV BIAORA	33KV SILPATI	7	15:17:00	97.95%
14	GUNA	132KV Chanderi	33KV BAMORE	11	14:27:00	98.06%
15	GUNA	132KV Chanderi	33KV SEHRAI	5	2:39:00	99.64%
16	GUNA	132KV ISAGARH	33KV DHAKONI	8	02:39:00	99.64%
17	GUNA	132KV ISAGARH	33KV NAI SARAI	5	02:58:00	99.60%
18	GUNA	132KV ISAGARH	33KV PARSOL	5	1:14:00	99.83%
19	GUNA	132KV KAPASI	33KV FATEHGARH	8	03:04:00	99.59%
20	GUNA	132KV KAPASI	33KV KALORA	15	11:37:00	98.44%
21	GUNA	132KV KAPASI	33KV KAPASI	30	21:06:00	97.16%
22	GUNA	132KV KAPASI	33KV MANA	28	11:35:00	98.44%
23	GUNA	132KV MAKSUDANGARH	33KV MAKSUDANGARH	6	06:19:00	99.15%
24	GUNA	132kv MUNGAWALI	33KV MUNGAWALI	9	15:39:00	97.90%
25	GUNA	132kv RAGHOGARH	33KV AWAN	6	02:52:00	99.61%
26	GUNA	132KV RAGHOGARH	33KV DHARNAWADA	7	01:42:00	99.77%
27	GUNA	132KV RAGHOGARH	33KV JAMNER I	5	05:16:00	99.29%
28	GUNA	132KV RAGHOGARH	33KV JP INSTITUTE	6	06:43:00	99.10%
29	GUNA	132KV RAGHOGARH	33KV KUMBHRAJ-II	13	11:47:00	98.42%
30	GUNA	132KV RAGHOGARH	33KV SAKATPUR	11	04:00:00	99.46%
31	GUNA	220KV ASHOKNAGAR	33KV IMLA	5	02:56:00	99.61%
32	GUNA	220KV ASHOKNAGAR	33KV MAHIDPUR	7	02:18:00	99.69%
33	GUNA	220KV ASHOKNAGAR	33KV MATHNER	14	19:30:00	97.38%
34	GUNA	220KV ASHOKNAGAR	33KV SEMRAHAT	18	13:28:00	98.19%
35	GUNA	220KV ASHOKNAGAR	33KV SHADORA	10	03:38:00	99.51%
36	GUNA	220KV GUNA	33KV BAJRANGGARH	13	09:33:00	98.72%
37	GUNA	220KV GUNA	33KV BEHTAGHAT	8	04:54:00	99.34%
38	GUNA	220KV GUNA	33KV GARHA	5	07:32:00	98.99%
39	GUNA	220KV GUNA	33KV GUNA	49	25:27:00	96.58%
40	GUNA	220KV GUNA	33KV HARIPUR	15	16:33:00	97.78%
41	GUNA	220KV GUNA	33KV MURADPUR	14	10:51:00	98.54%
42	GUNA	220KV GUNA	33KV NANAKHEDI	5	01:01:00	99.86%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Gwalior City Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Availability of feeder)
1	GWALIOR CITY	132kV MOTIHEEL	33KV WATER WORKS	6	08:14:00	98.89%
2	GWALIOR CITY	220KV MAHALGAON	33KV DARPAN COLONY-I	6	07:27:00	99.00%

EHV S/s wise No. of 33kV feeders interruption/Breakdown report of Gwalior O&M Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Availability of feeder)
1	GWALIOR(O&M)	132KV BHANDER	33KV MELA GROUND	7	08:34:00	98.85%
2	GWALIOR(O&M)	132KV DABRA	33KV BHITARWAR	18	10:04:00	98.65%
3	GWALIOR(O&M)	132KV DABRA	33KV CHIMAK	12	24:20:00	96.73%
4	GWALIOR(O&M)	132KV DABRA	33KV CHINNOR	6	15:14:00	97.95%
5	GWALIOR(O&M)	132KV DABRA	33KV MAGRORA	13	12:53:00	98.27%
6	GWALIOR(O&M)	132KV DABRA	33KV MASUDPUR	5	07:59:00	98.93%
7	GWALIOR(O&M)	132KV DABRA	33KV PICHHORE	11	07:18:00	99.02%
8	GWALIOR(O&M)	132KV DABRA	33KV TEKANPUR	5	11:01:00	98.52%
9	GWALIOR(O&M)	132KV INDERGARH	33KV INDERGARH	25	17:31:00	97.65%
10	GWALIOR(O&M)	132KV INDERGARH	33KV RARUA RAI	14	18:07:00	97.56%
11	GWALIOR(O&M)	132KV INDERGARH	33KV THARET	5	5:28:00	99.27%
12	GWALIOR(O&M)	132KV MOHANA	33KV MOHANA	14	11:47:00	98.42%
13	GWALIOR(O&M)	132KV MORAR	33KV RAIUR	6	19:01:00	97.44%
14	GWALIOR(O&M)	132KV SEONDHA	33KV BHAGUAPURA	8	16:11:00	97.82%
15	GWALIOR(O&M)	132KV SEONDHA	33KV LANCH	8	17:25:00	97.66%
16	GWALIOR(O&M)	132KV SEONDHA	33KV MANGROL	6	04:42:00	99.37%
17	GWALIOR(O&M)	132KV SEONDHA	33KV SEONDHA	12	2:35:00	99.65%
18	GWALIOR(O&M)	132KV TIGHARA	33KV BARAI	9	04:25:00	99.41%
19	GWALIOR(O&M)	132KV TIGHARA	33KV DWARKAPURI	6	03:44:00	99.50%
20	GWALIOR(O&M)	220KV DATIA2	33KV BADONI	6	03:02:00	99.59%
21	GWALIOR(O&M)	220KV DATIA2	33KV GORAGHAT	11	08:53:00	98.81%
22	GWALIOR(O&M)	220KV DATIA2	33KV SITAPUR	7	07:53:00	98.94%
23	GWALIOR(O&M)	220KV GWALIOR2	33KV BILAU	19	35:07:00	95.28%
24	GWALIOR(O&M)	220KV GWALIOR2	33KV INDUSTRIAL CRUSHER	23	19:13:00	97.42%
25	GWALIOR(O&M)	220KV MALANPUR	33KV FEEDER-IV	15	11:06:00	98.51%
26	GWALIOR(O&M)	220KV MALANPUR	33KV FEEDER-V	7	03:18:00	99.56%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Hoshangabad Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Availability of feeder)
1	HOSHANGABAD	132KV BANKHEDI	33KV ISHERPUR	6	04:06:00	99.45%
2	HOSHANGABAD	132KV BANKHEDI	33KV KARPA	7	09:25:00	98.73%
3	HOSHANGABAD	132KV BANKHEDI	33KV OLD BANKHEDI	7	05:34:00	99.25%
4	HOSHANGABAD	132KV HARDA	33KV ABGAON KHURD	26	10:19:00	98.61%
5	HOSHANGABAD	132KV HARDA	33KV HANDIA	5	01:15:00	99.83%
6	HOSHANGABAD	132KV HARDA	33KV KANKARIA	6	02:45:00	99.63%
7	HOSHANGABAD	132KV HARDA	33KV TIMARNI	5	06:08:00	99.18%
8	HOSHANGABAD	132KV HARDA	33kv VXL	54	86:10:00	88.42%
9	HOSHANGABAD	132KV KHIRKIYA	33KV CHARUA	6	01:34:00	99.79%
10	HOSHANGABAD	132KV KHIRKIYA	33KV KHIRKIYA-II	9	3:06:00	99.58%
11	HOSHANGABAD	132KV Piparia	33KV HT CONSUMER	11	09:11:00	98.77%
12	HOSHANGABAD	132KV Piparia	33KV SANDIYA	10	6:36:00	99.11%
13	HOSHANGABAD	132KV Piparia	33KV SHANKHINI	8	5:35:00	99.25%
14	HOSHANGABAD	132KV Piparia	33KV SHOBHAPUR	5	03:34:00	99.52%
15	HOSHANGABAD	132KV SEMRIHARCHAND	33KV M.A.F.	6	11:10:00	98.50%
16	HOSHANGABAD	132KV SEMRIHARCHAND	33KV MOHASA-I	5	5:30:00	99.26%
17	HOSHANGABAD	132KV SeoniMalwa	33KV DHARAMKUNDI	8	04:04:00	99.45%
18	HOSHANGABAD	132KV SeoniMalwa	33KV SURAJPUR	6	02:31:00	99.66%
19	HOSHANGABAD	132KV SULTANPUR	33KV MUHALKALA	16	22:49:00	96.93%
20	HOSHANGABAD	220KV HOSHANGABAD	33KV BUDNI	7	05:57:00	99.20%
21	HOSHANGABAD	220KV Itarsi	33KV ITARSI - II	6	07:34:00	98.98%
22	HOSHANGABAD	220KV Itarsi	33kv SPM	8	02:49:00	99.62%
23	HOSHANGABAD	220KV PIPARIA2	33KV BUS COUPLER	8	05:15:00	99.29%
24	HOSHANGABAD	220KV PIPARIA2	33KV KALLUKHAPA	8	02:21:00	99.68%
25	HOSHANGABAD	220KV PIPARIA2	33KV PACHMARHI	7	03:24:00	99.54%
26	HOSHANGABAD	220KV PIPARIA2	33KV PIPARPANI	8	02:56:00	99.61%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Morena Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performnce in % (Avalability of feeder)
1	MORENA	132KV AMBAH	33KV ESHAH	5	06:18:00	99.15%
2	MORENA	132KV AMBAH	33KV GOTH	6	06:59:00	99.06%
3	MORENA	132KV AMBAH	33KV GUNJBADA	7	07:08:00	99.04%
4	MORENA	132KV AMBAH	33KV THARA	7	04:06:00	99.45%
5	MORENA	132KV BANMORE	33/11KV X-MER-II(SMVA)	11	03:09:00	99.58%
6	MORENA	132KV BANMORE	33KV MAGNUM	36	18:56:00	97.46%
7	MORENA	132KV BANMORE	33KV NOORABAD	12	13:06:00	98.24%
8	MORENA	132kv DIMNI	33KV AJNODHA	6	08:35:00	98.85%
9	MORENA	132KV DIMNI	33KV BADAGAON	21	16:02:00	97.84%
10	MORENA	132KV DIMNI	33KV DIMNI	13	06:52:00	99.08%
11	MORENA	132KV JOURA	33KV BAGCHINI	9	11:30:00	98.45%
12	MORENA	132KV JOURA	33KV CHINNONI	20	13:11:00	98.23%
13	MORENA	132KV JOURA	33KV JOURA CITY	32	18:24:00	97.53%
14	MORENA	132KV JOURA	33KV JOURA-II	6	3:50:00	99.48%
15	MORENA	132KV JOURA	33KV KUMHERI	11	3:58:00	99.47%
16	MORENA	132KV JOURA	33KV SHANKARA	5	00:48:00	99.89%
17	MORENA	132KV KAILARAS	33KV KAILARAS	6	01:52:00	99.75%
18	MORENA	132KV KAILARAS	33KV PAHADGARH	8	7:44:00	98.96%
19	MORENA	132KV PORSA	33KV PORSA	5	1:29:00	99.80%
20	MORENA	220KV MORENA2	33KV JADERUA	5	14:11:00	98.09%
21	MORENA	220KV SABALGARH	33KV BADDPURA	5	04:58:00	99.33%
22	MORENA	220KV SABALGARH	33KV JHUNDPURA	12	05:25:00	99.27%
23	MORENA	220KV SABALGARH	33KV KAILARAS	9	06:18:00	99.15%
24	MORENA	220KV SABALGARH	33KV MAMCHONE	11	10:44:00	98.56%
25	MORENA	220KV SABALGARH	33KV RAMPUR	10	03:45:00	99.50%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Bhopal O&M Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Availability of feeder)
1	O&M BHOPAL	132KV Berasia	33KV RATUA	6	02:18:00	99.69%
2	O&M BHOPAL	132KV ENTKHEDI	33KV AKVN	33	09:52:00	98.67%
3	O&M BHOPAL	132KV ENTKHEDI	33KV ENTKHEDI-II	5	01:15:00	99.83%
4	O&M BHOPAL	132KV GOPALPUR	33KV GILLORE	19	08:22:00	98.88%
5	O&M BHOPAL	132KV GOPALPUR	33KV VASUDEV	9	02:20:00	99.69%
6	O&M BHOPAL	132KV Lalghati	33KV KHAJURI SADAK	16	08:28:00	98.86%
7	O&M BHOPAL	132KV MACT	33KV BADJHIRI	5	06:31:00	99.12%
8	O&M BHOPAL	132KV NASRULLAGANJ	33KV CHAKALDI	8	10:21:00	98.61%
9	O&M BHOPAL	132KV NASRULLAGANJ	33KV KANKARIA	10	16:57:00	97.72%
10	O&M BHOPAL	132KV NASRULLAGANJ	33KV NASRULLAGANJ	6	13:18:00	98.21%
11	O&M BHOPAL	132KV NASRULLAGANJ	33KV REHTI	11	16:15:00	97.82%
12	O&M BHOPAL	132KV SHAHGANJ	33KV DIGWAD	8	18:25:00	97.52%
13	O&M BHOPAL	132KV SHAHGANJ	33KV DOBI	13	32:42:00	95.60%
14	O&M BHOPAL	132KV SHAHGANJ	33KV NANDNER	14	35:37:00	95.21%
15	O&M BHOPAL	220KV Bairagarh	33KV ITKHEDI	10	10:13:00	98.63%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Raisen Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Avalability of feeder)
1	RAISEN	132KV Bareli	33KV HARSILY	5	01:38:00	99.78%
2	RAISEN	132KV Bareli	33KV KUNDALI	14	68:10:00	90.84%
3	RAISEN	132KV BARELI	33KV NAYAGAON KHURD	7	08:03:00	98.92%
4	RAISEN	132KV Gairatganj	33KV BEGUMGANJ	8	04:16:00	99.43%
5	RAISEN	132KV Gairatganj	33KV DEHGAON	6	6:45:00	99.09%
6	RAISEN	132KV GAIRATGANJ	33KV DHANDIYA	5	02:29:00	99.67%
7	RAISEN	132KV Gairatganj	33KV GAIRATGANJ	5	04:34:00	99.39%
8	RAISEN	132KV GAIRATGANJ	33KV SAMNAPUR	5	06:50:00	99.08%
9	RAISEN	132KV Gairatganj	33KV SILWANI	6	07:01:00	99.06%
10	RAISEN	132KV Raisen	33KV NEEMKHEDA	6	13:59:00	98.12%
11	RAISEN	132KV Raisen	33KV PAGNESHWAR	8	25:13:00	96.61%
12	RAISEN	132KV UDAIPURA	33KV BORAS	12	22:11:00	97.02%
13	RAISEN	132KV UDAIPURA	33KV THALA DIGHAWAN	12	23:49:00	96.80%
14	RAISEN	220KV MANDIDEEP2	33KV ARJUN NAGAR	10	27:22:00	96.32%
15	RAISEN	220KV MANDIDEEP2	33KV SIMARAI	7	19:07:00	97.43%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Rajgarh Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performnce in % (Avalability of feeder)
1	RAJGARH	132KV BIAORA	33KV BHOORA	9	17:56:00	97.59%
2	RAJGARH	132KV BIAORA	33KV PAGARI BANGLOW	17	25:25:00	96.58%
3	RAJGARH	132KV BIAORA	33KV WATER-WORKS	7	13:07:00	98.24%
4	RAJGARH	132KV Jeerapur	33KV JAITPURA	8	2:19:00	99.69%
5	RAJGARH	132KV Jeerapur	33KV JEERAPUR	5	01:24:00	99.81%
6	RAJGARH	132KV Jeerapur	33KV MACHALPUR	5	01:11:00	99.84%
7	RAJGARH	132KV Khilchipur	33KV BIORAKALA	18	13:56:00	98.13%
8	RAJGARH	132KV Khilchipur	33KV LAKHONI	8	10:53:00	98.54%
9	RAJGARH	132KV KHILCHIPUR	33KV SANDAWATA	17	15:52:00	97.87%
10	RAJGARH	132KV KURAWAR	33KV LASUDIYA BHAMA	6	11:32:00	98.45%
11	RAJGARH	132KV KURAWAR	33KV NARSINGHGARH	5	04:04:00	99.45%
12	RAJGARH	132KV PACHORE	33KV INDUSTRIAL	5	03:46:00	99.49%
13	RAJGARH	132KV SARANGPUR	33KV INDUSTRIAL	5	03:03:00	99.59%
14	RAJGARH	132KV SARANGPUR	33KV PADLIYAMATA-I	9	19:30:00	97.38%
15	RAJGARH	132KV SARANGPUR	33KV PADLIYAMATA-II	15	19:32:00	97.37%
16	RAJGARH	220KV RAJGARH2	33KV CHATUKHEDA	5	06:08:00	99.18%
17	RAJGARH	220KV RAJGARH2	33KV PIPLODI	12	05:54:00	99.21%
18	RAJGARH	220KV RAJGARH2	33KV WATER WORKS(A.I.R.)	9	09:54:00	98.67%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Sehore Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performnce in % (Avalability of feeder)
1	SEHORE	132KV Ashta	33kv KHACHROD	5	08:48:00	98.82%
2	SEHORE	132KV ICHHAWAR	33KV BHAUKHEDI	10	03:22:00	99.55%
3	SEHORE	132kv SHYAMPUR	33KV MUNGAWALI	5	16:34:00	97.77%
4	SEHORE	132kv SHYAMPUR	33KV SONKATCH	5	04:15:00	99.43%
5	SEHORE	220KV ASHTA2	33KV KAJLAS	6	03:53:00	99.48%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Sheopur Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Avalability of feeder)
1	SHEOPUR	132KV BARODA	33KV BARODA	16	08:29:00	98.86%
2	SHEOPUR	132KV BARODA	33KV SALMANYA	5	04:26:00	99.40%
3	SHEOPUR	132KV MOHANA	33KV SAHASRAM	18	34:51:00	95.32%
4	SHEOPUR	132KV SHEOPUR	33KV BAGDUWA	12	11:18:00	98.48%
5	SHEOPUR	132KV SHEOPUR	33KV BARODA	14	22:15:00	97.01%
6	SHEOPUR	132KV SHEOPUR	33KV BHOGIKA	13	19:26:00	97.39%
7	SHEOPUR	132KV SHEOPUR	33KV DHONTI	15	09:00:00	98.79%
8	SHEOPUR	132KV SHEOPUR	33KV GORUS	13	33:08:00	95.55%
9	SHEOPUR	132KV SHEOPUR	33KV JAIDA	5	06:27:00	99.13%
10	SHEOPUR	132KV SHEOPUR	33KV JANPURA	15	10:51:00	98.54%
11	SHEOPUR	132KV SHEOPUR	33KV KALARNA	5	03:42:00	99.50%
12	SHEOPUR	132KV SHEOPUR	33KV RAMBADI	7	27:27:00	96.31%
13	SHEOPUR	132KV SHEOPUR	33KV SOINKALAN	20	27:14:00	96.34%
14	SHEOPUR	132KV VIJAYPUR	33KV AGARA	9	06:33:00	99.12%
15	SHEOPUR	132KV VIJAYPUR	33KV BEERPUR	14	13:18:00	98.21%
16	SHEOPUR	132KV VIJAYPUR	33KV DORD	21	10:14:00	98.62%
17	SHEOPUR	132KV VIJAYPUR	33KV VIJAYPUR	13	02:31:00	99.66%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Shivpuri Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Availability of feeder)
1	SHIVPURI	132KV BAIRAD	33KV GOVARDHAN	9	03:20:00	99.55%
2	SHIVPURI	132KV KARERA	33KV BEHGANWA	6	06:08:00	99.18%
3	SHIVPURI	132KV KARERA	33KV DINARA	7	01:54:00	99.74%
4	SHIVPURI	132KV KARERA	33KV NARAUUA	13	11:56:00	98.40%
5	SHIVPURI	132KV KOLARAS	33KV CHANDORIYA	5	2:11:00	99.71%
6	SHIVPURI	132KV KOLARAS	33KV KAILDHAR	13	20:05:00	97.30%
7	SHIVPURI	132KV KOLARAS	33KV RAI	5	00:44:00	99.90%
8	SHIVPURI	132KV MADA	33KV KHAREIH	72	28:45:00	96.14%
9	SHIVPURI	132KV MADA	33KV MADA	16	20:53:00	97.19%
10	SHIVPURI	132KV PICHHORE	33KV KHOD	9	3:18:00	99.56%
11	SHIVPURI	132KV PICHHORE	33KV NAYA CHOURAHA	20	07:12:00	99.03%
12	SHIVPURI	132KV PICHHORE	33KV PADRA	6	4:29:00	99.40%
13	SHIVPURI	132KV PICHHORE	33KV PICHHORE TOWN	7	01:11:00	99.84%
14	SHIVPURI	132KV SHIVPURI	33KV BHAGORA	11	09:31:00	98.72%
15	SHIVPURI	132KV SHIVPURI	33KV PADORA	9	12:14:00	98.36%
16	SHIVPURI	132KV SHIVPURI	33KV PARIKSHA	19	05:02:00	99.32%
17	SHIVPURI	220KV SHIVPURI2	33KV BHESANA	11	02:45:00	99.63%
18	SHIVPURI	220KV SHIVPURI2	33KV NOHARI	6	03:30:00	99.53%

EHV S/s wise No. of 33kV feeders Interruption/Breakdown report of Vidisha Circle during the Month of December-2018

Sr. No.	Circle	S/S Name	Feeder Name	No. of Interruption	Total Off Duration	Performance in % (Avalability of feeder)
1	VIDISHA	132KV Sironj	33KV FEEDER-I((LATERI)	6	10:50:00	98.54%
2	VIDISHA	132KV Sironj	33KV MURWAS-I	6	07:31:00	98.99%
3	VIDISHA	132KV Sironj	33KV MURWAS-II(CHHAPU)	23	13:31:00	98.18%
4	VIDISHA	132KV Sironj	33KV SHAHPUR	7	02:16:00	99.70%
5	VIDISHA	132KV Sironj	33KV UHAR	23	10:42:00	98.56%
6	VIDISHA	220kv GANJBASODA	33KV BANWA JAGIR	19	11:13:00	98.49%
7	VIDISHA	220kv GANJBASODA	33KV JAIL	7	03:23:00	99.55%
8	VIDISHA	220kv GANJBASODA	33KV KANJANA PATHAR	15	03:38:00	99.51%
9	VIDISHA	220kv GANJBASODA	33KV SOMBARA	8	13:57:00	98.13%
10	VIDISHA	220KV VIDISHA	33KV BAN	6	07:07:00	99.04%
11	VIDISHA	220KV VIDISHA	33KV BRITANIA	5	17:20:00	97.67%
12	VIDISHA	220KV VIDISHA	33KV HASUA	7	03:08:00	99.58%
13	VIDISHA	220KV VIDISHA	33KV LASKARPUR	5	09:37:00	98.71%
14	VIDISHA	220KV VIDISHA	33KV MANORA	11	10:17:00	98.62%
15	VIDISHA	220KV VIDISHA	33KV SPARE BAY I	6	05:50:00	99.22%